DB2 DIELECTRIC BOOTS CLASS 2

17.5_{kV}
Maximum Working Voltge

20_{kV} Test Voltage

• Every boot tested to 20kV (AC testing as standard, DC testing available on request)

- Leakage current less than 5mA at 5kV and less than 18mA at 20kV

- Meets the requirements of ASTM 1117 (20kV) and ASTM 2413

- Blue vulcanized rubber sole for maximum grip - 30% better than a conventional safety boot sole

- Slip resistance performance twice that required by SATRA TM144 standard

• Two to three times the wear resistance of conventional soles

SIZE - 39 to 47



















